



NOTE: 1) SEAL ALL OPENINGS TO KEEP CEMENT MOIST TO PREVENT CRACKING.
 2) HYDRO @ 240 PSIG.
 3) EXTEND ALL CPLGS. 5/8" INSIDE.
 4) 4-22-04 PROOF TEST.

SHELL / HEADS	.245" SA-455 2:1 S.E.	CS-48-712-V	REV. 1-23-07
	JOGGLE - .208 OFFSET		DATE: 3-27-03
SHELL / HEADS	.200" SA-455	FOR: HANSON STANDARD	
		VERT. HOT WATER TANK.	
		113.0 SQ. FT. SURFACE AREA. THIS TANK IS SHIPPED WITH ALL OPENINGS SEALED. THE CEMENT LINING MUST BE KEPT MOIST BEFORE, DURING, AND AFTER INSTALLATION TO PREVENT CRACKING OF THE CEMENT.	
M.A.W.P.	160 PSIG. @ 210 °F	INSIDE: CEMENT LINED	
		OUTSIDE: PRIME	
ASME. SECTION	IV 2004 ADD. 2006	(680) LEG-ZONE 4-15 KM.	
X-RAY:	RT-NO / H.L.W.	CAD-"B" UNDER "STD"-SERIES	
GALLONS:	712	WT. 1986 LBS.	BY: J.G. SCALE: 3/4" = 1'
SERIAL NO.		ROY E. HANSON JR. MFG.	
N.B.		1600 E. WASHINGTON BLVD. LOS ANGELES, CA 90021	